



# Acoustical Surfaces, Inc.

SOUNDPROOFING, ACOUSTICS, NOISE & VIBRATION CONTROL SPECIALISTS

123 Columbia Court North • Suite 201 • Chaska, MN 55318  
(952) 448-5300 • Fax (952) 448-2613 • (800) 448-0121

Email: [sales@acousticalsurfaces.com](mailto:sales@acousticalsurfaces.com)  
Visit our Website: [www.acousticalsurfaces.com](http://www.acousticalsurfaces.com)

We Identify and **S.T.O.P.** Your Noise Problems

US-D-OPS-04-02-T



SGS U.S. Testing Company Inc.

1341 North 108th. East Avenue Tulsa, OK 74116 • Tel: 918-437-8333 Fax: • 918-437-8487

CLIENT: Rendered by Manufacturer and Released to:  
Acoustical Surfaces Inc.  
123 Columbia Court North, Suite 201  
Chaska, MN 55318

Test Report No. 167313 Date: May 9, 2002

SUBJECT: Quiet Liner Air Erosion Test  
REFERENCE: Letter  
SAMPLE ID: One complete ductwork with Quiet Liner installed was received from the client on 4/11/02. The sample was received in good condition.  
TEST REQUESTED: The evaluation was performed in accordance with ASTM C1071-00. Section 12.7. The test air velocity was set at 5000 ft/min. No revisions to this report will be allowed after 90 days of the revision date.  
TEST DATE: 4/09/02.  
RESULTS: No erosion was observed after 4 hours of exposure to an air velocity of 5000 ft/min. Maximum use Velocity: 2000 ft.min.  
CONCLUSION: The Quiet Liner does not comply with the requirements of ASTM C1071-00, Section 12.7.  
CERTIFICATION: The tests reported here were conducted under the continuous direct supervision of SGS U.S. Testing Company Inc., Tulsa, OK.

SIGNED FOR AND ON BEHALF OF  
SGS U.S. TESTING COMPANY INC.

Jeff Simmons  
bk Dept. Manager/Product Evaluation

Dale E. Holloway  
Tulsa Branch Director

This report is issued by SGS U.S. Testing Company Inc. under its General Conditions for Testing Services, as printed on reverse side. SGS U.S. Testing's responsibility under this report is limited to proven negligence and will in no case be more than the amount of the testing fees. Except by special arrangement, samples are not retained by SGS U.S. Testing for more than 30 days. The results shown on this test report refer only to the sample(s) tested unless otherwise stated under the conditions agreed upon. Anyone relying on this report should understand all of the details of the engagement. Neither the name, seals, marks nor insignia of SGS U.S. Testing may be used in any advertising or promotional materials without the prior written approval of SGS U.S. Testing. The test report cannot be reproduced, except in full, without prior written permission of SGS U.S. Testing Company.

Member of the SGS Group (Société Générale de Surveillance)

- Soundproofing Products • Sonex™ Ceiling & Wall Panels • Sound Control Curtains • Equipment Enclosures • Acoustical Baffles & Banners • Solid Wood & Veneer Acoustical Ceiling & Wall Systems
- Professional Audio Acoustics • Vibration & Damping Control • Fire Retardant Acoustics • Hearing Protection • Moisture & Impact Resistant Products • Floor Impact Noise Reduction
- Sound Absorbers • Noise Barriers • Fabric Wrapped Wall Panels • Acoustical Foam (Egg Crate) • Acoustical Sealants & Adhesives • Outdoor Noise Control • Assistive Listening Devices
- OSHA, FDA, ADA Compliance • On-Site Acoustical Analysis • Acoustical Design & Consulting • Large Inventory • Fast Shipment • No Project too Large or Small • Major Credit Cards Accepted